


**TESTCONSULT**  
TESTING AND CONSULTING SERVICES

## TEST CERTIFICATE

### Pedestrian Barrier



**Client: A- FAX Ltd**  
Shady Lane  
Halifax  
HX3 6RL

Ref No: S2779  
Job No: A4722  
Date Tested: 10/10/2005  
Date Reported: 20/10/2005

**Site:** Testconsult Ltd, Ruby House, 40A Hardwick Grange, Woolston, Warrington, Cheshire, WA1 4RF  
**Barrier System:** Pedestrian Barrier  
**Test Specification:** BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers.  
**Test Engineer:** Mark Mairs / Lee Waterhouse

Test No.	Test Specification	Load (KN)	Max Deflection (mm)	Remarks (Pass/Fail)
1	Horizontal uniformly Distributed line load (kN/m)	1.5	56	Conforms to BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers. PASS
2	A uniformly distributed load applied to the infill (kN/m <sup>2</sup> )	1.5	31	Conforms to BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers. PASS
3	A point load applied to part of the infill (kN)	1.5	93	Conforms to BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers. PASS

**Lee Waterhouse**  
Instrumentation Engineer  
**TESTCONSULT LIMITED**